

AnnexureC

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No : 01

Dated:18.02.2026

It is certified that an inspection team headed by Mr. Shailesh L. Patel (Name of Officers with designation) from SWM Department inspected the Delhi Public School – Bopal, Ahmedabad (Name & Address of the school) on 24.01.2026 (date of inspection) and on the basis of Water Test Report (Attached) bearing no. 651-656 / 2025-26 dated 17.12.2025 of DISTRICT LABORATORY – Gujarat Water Supply & Sewerage Board, Ahmedabad (PHED Lab) certified that the Delhi Public School – Bopal, Ahmedabad (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 31.12.2026



Signature with Seal:

Name : Shailesh L. Patel

Designation: Public Health Supervisor

Name & Address of the Office / Department : Swm Dept., Thaltej

To
Delhi Public School-Bopal,
Ahmedabad



DISTRICT LABORATORY
Gujarat Water Supply & Sewerage Board
AHMEDABAD

Test Report

***Name & Address of Customer:-**

Delhi Public School

*Customer Reference No.:2025-12-15-651

Bopal Square, Near Railway Crossing ,Bopal

*Sample Submitted by :Customer

Ahmedabad

*Date of Sample Receipt :15-Dec-2025

Ahmedabad

Analysis Starting Date :16-Dec-2025

0

Analysis Completion Date :16-Dec-2025

Dicipline:Chemical Testing,Group:Drinking Water

Test Report No.: 651/2025-26

Date of issue : 17-Dec-2025

Sample ID : ACW -651/12-2025

*Customer ID :Satisfactory

*Main Source :Ground Water

*Source :Tube Well

*Location :Chanakya building

*Village :Bopal

*Habitation :Bopal

*Taluka :Daskroi

*District :Ahmedabad

*Latitude :

*Longitude :

Kindly find herewith the Analytical Results.

Sample Type : Drinking Water


r.N	Parameter	Unit	Reference Method :	Analytical Value
1	Colour	Hazen	APHA (24th Ed.2023), Method: 2120 C	<1
2	Odour	-	IS : 3025 (Part 5) - 2018	Agreeable
3	Taste	-	IS : 3025 (Part 8) - 1984	Agreeable
4	Turbidity	NTU	APHA (24th Ed.2023), Method: 2130 B	0.97
5	pH at 25°C	-	APHA (24th Ed.2023) Method: 4500 H ⁺ B	7.19
6	Conductivity at 25°C	µS/cm	APHA (24th Ed.2023) Method: 2510 B	2797
7	Total Dissolved Solids(180°C)	mg/L	APHA (24th Ed.2023) Method: 2540 C	1790
8	Total Hardness(as CaCO ₃)	mg/L	APHA (24th Ed.2023) Method: 2340 C	372
9	Calcium (as Ca ⁺²)	mg/L	APHA (24th Ed.2023) Method: 3500 Ca ⁺² B	64
10	Magnesium (as Mg ⁺²)	mg/L	APHA (24th Ed.2023) Method: 3500-Mg ⁺² B	51
11	Chloride (as Cl ⁻)	mg/L	APHA (24th Ed.2023) Method: 4500-Cl ⁻ B	796
12	Sulphate (as SO ₄ ⁻²)	mg/L	APHA (24th Ed.2023) Method: 4500-SO ₄ ⁻² E	110
13	Nitrate (as NO ₃ ⁻)	mg/L	APHA (24th Ed.2023) Method: 4500-NO ₃ ⁻ B	29.80
14	Fluoride (as F ⁻)	mg/L	APHA (24th Ed.2023) Method: 4500-F ⁻ C	0.25
15	Total Alkalinity(as CaCO ₃)	mg/L	APHA (24th Ed.2023) Method: 2320 B	264

This Report is issued under the following terms & Condition :

1. This report is referring only to the tested sample and for applicable parameter.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part, and can't be used be as evidence in court of law.
4. Please refer back page for IS 10500:2012 (2nd Revision) limits.
5. Details marked by * is provied by customer.

Checked By:

Mayur J Rathod
Mayur J Rathod
(Analyst)



Issued By:

Vibhuti R Jadav
Vibhuti R Jadav
(Co-Ordinator)

O.W.No. DLA/ 159 /of 2025, Dt. 26 12 2025

.....End of the Test Report.....

5th Floor, jalbhavan, Behind Town Hall, Ellisbridge, Ahmedabad-380006

TelePhone No.:-9978441113 to 17 E-mail: jalbhavan.lab@gmail.com



QF-DL/7.8/F-01

DISTRICT LABORATORY
Gujarat Water Supply & Sewerage Board
AHMEDABAD

Test Report

***Name & Address of Customer:-**

Delhi Public School

***Customer Reference No.:**2025-12-15-652

Bopal Square, Near Railway Crossing ,Bopal

***Sample Submitted by :**Customer

Ahmedabad

***Date of Sample Receipt :**15-Dec-2025

Ahmedabad

Analysis Starting Date :16-Dec-2025

0

Analysis Completion Date :16-Dec-2025

Dicipline:Chemical Testing,**Group:**Drinking Water

Test Report No.: 652/2025-26

Date of Issue : 17-Dec-2025

Sample ID : ACW -652/12-2025

***Customer ID :**Satisfactory

***Main Source :**Ground Water

***Source :**RO Plant

***Location :**Chanakya building

***Village :**Bopal

***Habitation :**Bopal

***Taluka :**Daskroi

***District :**Ahmedabad

***Latitude :**

***Longitude :**

Kindly find herewith the Analytical Results.

Sample Type : Drinking Water

r.N	Parameter	Unit	Reference Method :	Analytical Value
1	Colour	Hazen	APHA (24th Ed.2023), Method: 2120 C	<1
2	Odour	-	IS : 3025 (Part 5) - 2018	Agreeable
3	Taste	-	IS : 3025 (Part 8) - 1984	Agreeable
4	Turbidity	NTU	APHA (24th Ed.2023), Method: 2130 B	0.31
5	pH at 25°C	-	APHA (24th Ed.2023) Method: 4500 H ⁺ B	7.15
6	Conductivity at 25°C	µS/cm	APHA (24th Ed.2023) Method: 2510 B	594
7	Total Dissolved Solids(180°C)	mg/L	APHA (24th Ed.2023) Method: 2540 C	380
8	Total Hardness(as CaCO ₃)	mg/L	APHA (24th Ed.2023) Method: 2340 C	172
9	Calcium (as Ca ⁺²)	mg/L	APHA (24th Ed.2023) Method: 3500 Ca ⁺² B	22
10	Magnessium (as Mg ⁺²)	mg/L	APHA (24th Ed.2023) Method: 3500-Mg ⁺² B	28
11	Chloride (as Cl ⁻)	mg/L	APHA (24th Ed.2023) Method: 4500-Cl ⁻ B	72
12	Sulphate (as SO ₄ ⁻²)	mg/L	APHA (24th Ed.2023) Method: 4500-SO ₄ ⁻² E	31
13	Nitrate (as NO ₃ ⁻)	mg/L	APHA (24th Ed.2023) Method: 4500-NO ₃ ⁻ B	6.63
14	Fluoride (as F ⁻)	mg/L	APHA (24th Ed.2023) Method: 4500-F ⁻ C	0.05
15	Total Alkalinity(as CaCO ₃)	mg/L	APHA (24th Ed.2023) Method: 2320 B	56

This Report is issued under the following terms & Condition :

1. This report is referring only to the tested sample and for applicable parameter.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part, and can't be used be as evidence in court of law.
4. Please refer back page for IS 10500:2012 (2nd Revision) limits.
5. I Details marked by * is provided by customer.

Checked By:

Mayur J Rathod
(Analyst)



Issued By:

Vibhuti R Jadav
(Co-Ordinator)

159

.....End of the Test Report.....

O.W.No. DLA/ /of 2025,Dt. 16/12/2025

5th Floor,jalbhavan,Behind Town Hall,Ellisbridge,Ahmedabad-380006
TelePhone No.:-9978441113 to 17 E-mail: jalbhavan.lab@gmail.com



QF-DL/7.8/F-01

DISTRICT LABORATORY
Gujarat Water Supply & Sewerage Board
AHMEDABAD

Test Report

***Name & Address of Customer:-**

Delhi Public School

***Customer Reference No.:**2025-12-15-653

Bopal Square, Near Railway Crossing ,Bopal

***Sample Submitted by :**Customer

Ahmedabad

***Date of Sample Receipt :**15-Dec-2025

Ahmedabad

Analysis Starting Date :16-Dec-2025

0

Analysis Completion Date :16-Dec-2025

Dicipline:Chemical Testing,Group:Drinking Water

Test Report No.: 653/2025-26

Date of Issue : 17-Dec-2025

Sample ID : ACW -653/12-2025

***Customer ID :**Satisfactory

***Main Source :**Ground Water

***Source :**RO Plant

***Location :**Dronacharya building

***Village :**Bopal

***Habitation :**Bopal

***Taluka :**Daskroi

***District :**Ahmedabad

***Latitude :**

***Longitude :**

Kindly find herewith the Analytical Results.

Sample Type : Drinking Water

r.N	Parameter	Unit	Reference Method :	Analytical Value
1	Colour	Hazen	APHA (24th Ed.2023), Method: 2120 C	<1
2	Odour	-	IS : 3025 (Part 5) - 2018	Agreeable
3	Taste	-	IS : 3025 (Part 8) - 1984	Agreeable
4	Turbidity	NTU	APHA (24th Ed.2023), Method: 2130 B	0.33
5	pH at 25°C	-	APHA (24th Ed.2023) Method: 4500 H ⁺ B	7.25
6	Conductivity at 25°C	µS/cm	APHA (24th Ed.2023) Method: 2510 B	463
7	Total Dissolved Solids(180°C)	mg/L	APHA (24th Ed.2023) Method: 2540 C	296
8	Total Hardness(as CaCO ₃)	mg/L	APHA (24th Ed.2023) Method: 2340 C	132
9	Calcium (as Ca ⁺²)	mg/L	APHA (24th Ed.2023) Method: 3500 Ca ⁺² B	11
10	Magnessium (as Mg ⁺²)	mg/L	APHA (24th Ed.2023) Method: 3500-Mg ⁺² B	25
11	Chloride (as Cl ⁻)	mg/L	APHA (24th Ed.2023) Method: 4500-Cl ⁻ B	52
12	Sulphate (as SO ₄ ⁻²)	mg/L	APHA (24th Ed.2023) Method: 4500-SO ₄ ⁻² E	22
13	Nitrate (as NO ₃ ⁻)	mg/L	APHA (24th Ed.2023) Method: 4500-NO ₃ ⁻ B	4.00
14	Fluoride (as F ⁻)	mg/L	APHA (24th Ed.2023) Method: 4500-F ⁻ C	0.52
15	Total Alkalinity(as CaCO ₃)	mg/L	APHA (24th Ed.2023) Method: 2320 B	52

This Report is issued under the following terms & Condition :

1. This report is referring only to the tested sample and for applicable parameter.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part, and can't be used be as evidence in court of law.
4. Please refer back page for IS 10500:2012 (2nd Revision) limits.
5. I Details marked by * is provied by custome

Checked By:

Mayur J Rathod
(Analyst)



Issued By:

Vibhuti R Jadav
(Co-Ordinator)

O.W.No. DLA/ 159 of 2025, Dt. 16 12 2025

5th Floor, jalbhavan, Behind Town Hall, Ellisbridge, Ahmedabad-380006

TelePhone No.:-9978441113 to 17 E-mail: jalbhavan.lab@gmail.com



DISTRICT LABORATORY
Gujarat Water Supply & Sewerage Board
AHMEDABAD

Test Report

*Name & Address of Customer:-

Delhi Public School

*Customer Reference No.:2025-12-15-654

Bopal Square, Near Railway Crossing ,Bopal

*Sample Submitted by :Customer

Ahmedabad

*Date of Sample Receipt :15-Dec-2025

Analysis Starting Date :16-Dec-2025

Ahmedabad

Analysis Completion Date :16-Dec-2025

0

Dicipline:Chemical Testing,Group:Drinking Water

Test Report No.: 654/2025-26

Date of Issue : 17-Dec-2025

Sample ID : ACW -654/12-2025

*Customer ID :Satisfactory

*Main Source :Ground Water

*Source :RO Plant

*Location :Radhakishana building

*Village :Bopal

*Habitation :Bopal

*Taluka :Daskroi

*District :Ahmedabad

*Latitude :

*Longitude :

Kindly find herewith the Analytical Results.

Sample Type : Drinking Water

r.N	Parameter	Unit	Reference Method :	Analytical Value
1	Colour	Hazen	APHA (24th Ed.2023), Method: 2120 C	<1
2	Odour	-	IS : 3025 (Part 5) - 2018	Agreeable
3	Taste	-	IS : 3025 (Part 8) - 1984	Agreeable
4	Turbidity	NTU	APHA (24th Ed.2023), Method: 2130 B	0.12
5	pH at 25°C	-	APHA (24th Ed.2023) Method: 4500 H ⁺ B	7.38
6	Conductivity at 25°C	µS/cm	APHA (24th Ed.2023) Method: 2510 B	487
7	Total Dissolved Solids(180°C)	mg/L	APHA (24th Ed.2023) Method: 2540 C	312
8	Total Hardness(as CaCO ₃)	mg/L	APHA (24th Ed.2023) Method: 2340 C	136
9	Calcium (as Ca ⁺²)	mg/L	APHA (24th Ed.2023) Method: 3500 Ca ⁺² B	18
10	Magnesium (as Mg ⁺²)	mg/L	APHA (24th Ed.2023) Method: 3500-Mg ⁺² B	22
11	Chloride (as Cl ⁻)	mg/L	APHA (24th Ed.2023) Method: 4500-Cl ⁻ B	64
12	Sulphate (as SO ₄ ⁻²)	mg/L	APHA (24th Ed.2023) Method: 4500-SO ₄ ⁻² E	21
13	Nitrate (as NO ₃ ⁻)	mg/L	APHA (24th Ed.2023) Method: 4500-NO ₃ ⁻ B	1.91
14	Fluoride (as F ⁻)	mg/L	APHA (24th Ed.2023) Method: 4500-F ⁻ C	0.02
15	Total Alkalinity(as CaCO ₃)	mg/L	APHA (24th Ed.2023) Method: 2320 B	44

This Report is issued under the following terms & Condition :

1. This report is referring only to the tested sample and for applicable parameter.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part, and can't be used be as evidence in court of law.
4. Please refer back page for IS 10500:2012 (2nd Revision) limits.
5. I Details marked by * is provied by customer

Checked By:

Mayur J Rathod
(Analyst)



Issued By:

Vibhuti R Jadav
(Co-Ordinator)

O.W.No. DLA/ 159 /of 2025, Dt. 16/12/2025

5th Floor, jalbhavan, Behind Town Hall, Ellisbridge, Ahmedabad-380006
TelePhone No.:-9978441113 to 17 E-mail: jalbhavan.lab@gmail.com



DISTRICT LABORATORY
Gujarat Water Supply & Sewerage Board
AHMEDABAD

Test Report

*Name & Address of Customer:-

Delhi Public School

*Customer Reference No.:2025-12-15-655

Bopal Square, Near Railway Crossing ,Bopal

*Sample Submitted by :Customer

Ahmedabad

*Date of Sample Receipt :15-Dec-2025

Ahmedabad

Analysis Starting Date :16-Dec-2025

0

Analysis Completion Date :16-Dec-2025

Discipline:Chemical Testing,Group:Drinking Water

Test Report No.: 655/2025-26

Date of Issue : 17-Dec-2025

Sample ID : ACW -655/12-2025

*Customer ID :Satisfactory

*Main Source :Ground Water

*Source :RO Plant

*Location :kishana building

*Village :Bopal

*Habitation :Bopal

*Taluka :Daskroi

*District :Ahmedabad

*Latitude :

*Longitude :

Kindly find herewith the Analytical Results.

Sample Type : Drinking Water


r.N	Parameter	Unit	Reference Method :	Analytical Value
1	Colour	Hazen	APHA (24th Ed.2023), Method: 2120 C	<1
2	Odour	-	IS : 3025 (Part 5) - 2018	Agreeable
3	Taste	-	IS : 3025 (Part 8) - 1984	Agreeable
4	Turbidity	NTU	APHA (24th Ed.2023), Method: 2130 B	0.27
5	pH at 25°C	-	APHA (24th Ed.2023) Method: 4500 H ⁺ B	7.41
6	Conductivity at 25°C	µS/cm	APHA (24th Ed.2023) Method: 2510 B	659
7	Total Dissolved Solids(180°C)	mg/L	APHA (24th Ed.2023) Method: 2540 C	422
8	Total Hardness(as CaCO ₃)	mg/L	APHA (24th Ed.2023) Method: 2340 C	180
9	Calcium (as Ca ⁺²)	mg/L	APHA (24th Ed.2023) Method: 3500 Ca ⁺² B	13
10	Magnesium (as Mg ⁺²)	mg/L	APHA (24th Ed.2023) Method: 3500-Mg ⁺² B	36
11	Chloride (as Cl ⁻)	mg/L	APHA (24th Ed.2023) Method: 4500-Cl ⁻ B	96
12	Sulphate (as SO ₄ ⁻²)	mg/L	APHA (24th Ed.2023) Method: 4500-SO ₄ ⁻² E	25
13	Nitrate (as NO ₃ ⁻)	mg/L	APHA (24th Ed.2023) Method: 4500-NO ₃ ⁻ B	2.54
14	Fluoride (as F ⁻)	mg/L	APHA (24th Ed.2023) Method: 4500-F ⁻ C	0.04
15	Total Alkalinity(as CaCO ₃)	mg/L	APHA (24th Ed.2023) Method: 2320 B	56

This Report is issued under the following terms & Condition :


1. This report is referring only to the tested sample and for applicable parameter.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part, and can't be used be as evidence in court of law.
4. Please refer back page for IS 10500:2012 (2nd Revision) limits.
5. I Details marked by * is provided by customer.

Checked By:


Mayur J Rathod
(Analyst)



Issued By:


Vibhuti R Jadav
(Co-Ordinator)

.....End of the Test Report.....
O.W.No. DLA/ 159 /of 2025,Dt. 16 / 12 /2025
5th Floor,jalbhavan,Behind Town Hall,Ellisbridge,Ahmedabad-380006
TelePhone No.:9978441113 to 17 E-mail: jalbhavan.lab@gmail.com



DISTRICT LABORATORY
Gujarat Water Supply & Sewerage Board
AHMEDABAD

Test Report

***Name & Address of Customer:-**

Delhi Public School

*Customer Reference No.:2025-12-15-656

Bopal Square, Near Railway Crossing ,Bopal

*Sample Submitted by :Customer

Ahmedabad

*Date of Sample Receipt :15-Dec-2025

Analysis Starting Date :16-Dec-2025

Ahmedabad

Analysis Completion Date :16-Dec-2025

0

Dicipline:Chemical Testing,Group:Drinking Water

Test Report No.: 656/2025-26

Date of Issue : 17-Dec-2025

Sample ID : ACW -656/12-2025

*Customer ID :Satisfactory

*Main Source :Ground Water

*Source :RO Plant

*Location :Gargi building

*Village :Bopal

*Habitation :Bopal

*Taluka :Daskroi

*District :Ahmedabad

*Latitude :

*Longitude :

Kindly find herewith the Analytical Results.

Sample Type : Drinking Water


r.No	Parameter	Unit	Reference Method :	Analytical Value
1	Colour	Hazen	APHA (24th Ed.2023), Method: 2120 C	<1
2	Odour	-	IS : 3025 (Part 5) - 2018	Agreeable
3	Taste	-	IS : 3025 (Part 8) - 1984	Agreeable
4	Turbidity	NTU	APHA (24th Ed.2023), Method: 2130 B	0.47
5	pH at 25°C	-	APHA (24th Ed.2023) Method: 4500 H ⁺ B	7.22
6	Conductivity at 25°C	µS/cm	APHA (24th Ed.2023) Method: 2510 B	434
7	Total Dissolved Solids(180°C)	mg/L	APHA (24th Ed.2023) Method: 2540 C	278
8	Total Hardness(as CaCO ₃)	mg/L	APHA (24th Ed.2023) Method: 2340 C	72
9	Calcium (as Ca ⁺²)	mg/L	APHA (24th Ed.2023) Method: 3500 Ca ⁺² B	18
10	Magnesium (as Mg ⁺²)	mg/L	APHA (24th Ed.2023) Method: 3500-Mg ⁺² B	7
11	Chloride (as Cl ⁻)	mg/L	APHA (24th Ed.2023) Method: 4500-Cl ⁻ B	96
12	Sulphate (as SO ₄ ⁻²)	mg/L	APHA (24th Ed.2023) Method: 4500-SO ₄ ⁻² E	19
13	Nitrate (as NO ₃ ⁻)	mg/L	APHA (24th Ed.2023) Method: 4500-NO ₃ ⁻ B	2.73
14	Fluoride (as F ⁻)	mg/L	APHA (24th Ed.2023) Method: 4500-F ⁻ C	0.05
15	Total Alkalinity(as CaCO ₃)	mg/L	APHA (24th Ed.2023) Method: 2320 B	64

This Report is issued under the following terms & Condition :

1. This report is referring only to the tested sample and for applicable parameter.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part, and can't be used be as evidence in court of law.
4. Please refer back page for IS 10500:2012 (2nd Revision) limits.
5. I Details marked by * is provied by customer.

Checked By:

Mayur J Rathod
 (Analyst)



Issued By:

Vibhuti R Gadav
 (Co-Ordinator)

.....End of the Test Report.....

O.W.No. DLA/ 159 of 2025, Dt. 16/12/2025

5th Floor, jalbhavan, Behind Town Hall, Ellisbridge, Ahmedabad-380006

Telephone No.:-9978441113 to 17 E-mail: jalbhavan.lab@gmail.com